



UIU PAIRING INSTRUCTION

Procedure:

Pairing operation for the User Interface Unit (UIU) to the Water Management Device (WMD) is as follows:

- #999# serial number # Standard operation
- #999#41142356847# Example
- ## Standard operation, attempting to pair
- ## Finalizing Sync

***Please Note this operation must be done for full functionality of the User Interface Unit**